

Aquatière®

IMMERSIBLE WATER TREATMENT MODULES

The cold water storage tank should be cleaned and flushed with clean water prior to installation.

Place the module in the water storage tank at an angle on the side wall nearest the inlet.

If you are installing 2 modules place one near the inlet and one near the outlet(s).

The units should be flushed with clean water on a 6 monthly basis.

